



Week 10 – March 09 – March 15, 2020

## Weekly CCR Landfill Inspection Form

### Inspection for Structural Weakness on GREC CCR Landfill:

*The inspector shall inspect for: surface cracks both transverse or longitudinal; slides, sinkholes, or depressions; missing vegetative cover; animal burrows; vegetation larger than two (2) inches in diameter; accumulated liquid; and surface discoloration indicating ash discharge from the landfill.*

#### Inspection Findings:

Light Wildlife surface damage repeat.

#### Action Taken:

Animal control and surface repair proceeding.

### Inspection for Excessive Fugitive Dust and Proper Operations to Minimize Fugitive Dust:

#### Inspection Findings:

None

#### Action Taken:

None

Inspected by: Doug Vore

Date of Inspection: 3/09/2020

Signed: 

Reviewed By: 