



Weekly CCR Landfill Inspection Form

Inspection for Structural Weakness on GREC CCR Landfill:
The inspector shall inspect for: surface cracks both transverse or longitudinal; slides, sinkholes, or depressions; missing vegetative cover; animal burrows; vegetation larger than two (2) inches in diameter; accumulated liquid; and surface discoloration indicating ash discharge from the landfill.

Inspection Findings:
Light Wildlife surface damage repeat.

Action Taken:
Animal control and surface repair proceeding.

Inspection for Excessive Fugitive Dust and Proper Operations to Minimize Fugitive Dust:

Inspection Findings:
None

Action Taken:
None

Inspected by: Doug Vore

Date of Inspection: 3/16/2020

Signed: 

Reviewed By: 