

Weekly CCR Landfill Inspection Form

Inspection for Structural Weakness on GREC CCR Landfill:

The inspector shall inspect for: surface cracks both transverse or longitudinal; slides, sinkholes, or depressions; missing vegetative cover; animal burrows; vegetation larger than two (2) inches in diameter; accumulated liquid; and surface discoloration indicating ash discharge from the landfill.

discoloration indicating ash discharge from the landfill.
Inspection Findings:
Light wildlife traffic
Slight erosion near top on Southeast corner
3 foot tall tree noticed on top of landfill near the SE corner
Action Taken:

Animal control

Reseed as part of routine maintenance of vegetative cover

Remove tree

Inspection for Excessive Fugitive Dust and Proper Operations to Minimize Fugitive Dust:

Inspection Findings: None

Action Taken: None

Inspected by: Travis Hinshaw	Date:	4-15-2020	
Signed by:			
Reviewed by: Michael L Bednar			