

Weekly CCR Landfill Inspection Form

Inspection for Structural Weakness on GREC CCR Landfill: The inspector shall inspect for: surface cracks both transverse or longitudinal; slides, sinkholes, or depressions; missing vegetative cover; animal burrows; vegetation larger than two (2) inches in diameter; accumulated liquid; and surface discoloration indicating ash discharge from the landfill.	
Inspection Findings:	
No new wildlife surface damage.	
Action Taken:	-
Animal control and surface repair proceeding.	
Inspection for Excessive Fugitive Dust and Proper	Operations to Minimize Fugitive Dust:
Inspection Findings:	
None	
Action Taken:	
None	
nspected by: Doug Vore	Date of Inspection: 3/23/2020
)	
Signed:	
Reviewed By: Maril and for	