



Week 21-May 25th-May 31st

Weekly CCR Landfill Inspection Form

<p align="center">Inspection for Structural Weakness on GREC CCR Landfill:</p> <p><i>The inspector shall inspect for: surface cracks both transverse or longitudinal; slides, sinkholes, or depressions; missing vegetative cover; animal burrows; vegetation larger than two (2) inches in diameter; accumulated liquid; and surface discoloration indicating ash discharge from the landfill.</i></p>
<p>Inspection Findings:</p> <p>Light wildlife traffic Slight erosion near top on Southeast corner</p>
<p>Action Taken:</p> <p>Animal control Reseed as part of routine maintenance of vegetative cover</p>

<p align="center">Inspection for Excessive Fugitive Dust and Proper Operations to Minimize Fugitive Dust:</p>
<p>Inspection Findings: None</p>
<p>Action Taken: None</p>

Inspected by: T. Hinshaw Date: 5-27-2020

Signed by: 

Reviewed by: Michael L. Bednar

