



Week 22-June 1-June 7

Weekly CCR Landfill Inspection Form

Inspection for Structural Weakness on GREC CCR Landfill:

The inspector shall inspect for: surface cracks both transverse or longitudinal; slides, sinkholes, or depressions; missing vegetative cover; animal burrows; vegetation larger than two (2) inches in diameter; accumulated liquid; and surface discoloration indicating ash discharge from the landfill.

Inspection Findings:

Light wildlife traffic
Slight erosion near top on Southeast corner

Action Taken:

Animal control
This area will be utilized as an entrance to the top of the landfill for construction and maintenance and suitably maintained.

Inspection for Excessive Fugitive Dust and Proper Operations to Minimize Fugitive Dust:

Inspection Findings: None

Action Taken: None

Inspected by: T. Hinshaw

Date: 6-03-2020

Signed by: 

Reviewed by: Michael L. Bednar