



Week 17 – April 25<sup>th</sup> – May 1<sup>st</sup>

**Weekly CCR Landfill Inspection Form**

<p align="center"><b>Inspection for Structural Weakness on GREC CCR Landfill:</b></p> <p><i>The inspector shall inspect for: surface cracks both transverse or longitudinal; slides, sinkholes, or depressions; missing vegetative cover; animal burrows; vegetation larger than two (2) inches in diameter; accumulated liquid; and surface discoloration indicating ash discharge from the landfill.</i></p>
<p><b><u>Inspection Findings:</u></b></p> <p>None</p>
<p><b><u>Action Taken:</u></b></p> <p>N/A</p>

<p align="center"><b>Inspection for Excessive Fugitive Dust and Proper Operations to Minimize Fugitive Dust:</b></p>
<p><b><u>Inspection Findings:</u></b></p> <p>None</p>
<p><b><u>Action Taken:</u></b></p> <p>N/A</p>

Inspected by: Maria Saucedo

Date of Inspection: Tue-04/26/2022

Signed: 