

Weekly CCR Landfill Inspection Form

Inspection for Structural Weakness on GREC CCR Landfill:
The inspector shall inspect for: surface cracks both transverse or longitudinal; slides, sinkholes, or depressions; missing vegetative cover; animal burrows; vegetation larger than two (2) inches in diameter; accumulated liquid; and surface discoloration indicating ash discharge from the landfill.

Inspection Findings:
none

Action Taken:
none

Inspection for Excessive Fugitive Dust and Proper Operations to Minimize Fugitive Dust:

Inspection Findings:
none

Action Taken:
none

Inspected by: Randy Boyle

Signed: Randy Boyle (Print)

Date: 1-5-14

Reviewed By: C/EX