

Weekly CCR Landfill Inspection Form

Inspection for Structural Weakness on GREC CCR Landfill: The inspector shall inspect for: surface cracks both transverse or longitudinal; slides, sinkholes, or depressions; missing vegetative cover; animal burrows; vegetation larger than two (2) inches in diameter; accumulated liquid; and surface discoloration indicating ash discharge from the landfill.		
Inspection Findi	ngs:	
,	NO EXCEPTIONS	
Action Taken:		_
	NONE TAKEN	
Inspection for	Excessive Fugitive Dust and Proper Operations to Minimize Fugitive Dust:	
Inspection Finding		_
	No Exceptions	
Action Taken:		_
_	NOME TAKEN	
Inspected by: _	Randy Bagle Randy Bagle Date: 2-17-16	
Reviewed By:	a Cara	