

Weekly CCR Landfill Inspection Form

Inspection for Structural Weakness on GREC CCR Landfill:

The inspector shall inspect for: surface cracks both transverse or longitudinal; slides, sinkholes, or depressions; missing vegetative cover; animal burrows; vegetation larger than two (2) inches in diameter; accumulated liquid; and surface discoloration indicating ash discharge from the landfill.

Inspection Findings:

EROSION ROWS/AREAS NORTH WEST SLOPE OF ASH LANDFILL;
2-3 FT IN LENGTH; 4 AREAS TO CORRECT

Action Taken:

Fill back with top soil then re-seed with fescue grass

Inspection for Excessive Fugitive Dust and Proper Operations to Minimize Fugitive Dust:

Inspection Findings:

NO DEFECTS

Action Taken:

NONE TAKEN

Inspected by: Randy Boyle

Signed: (Print)
Randy Boyle

Date: 3-28-17

Reviewed By: AC