

Weekly CCR Landfill Inspection Form

Inspection for Structural Weakness on GREC CCR Landfill:

The inspector shall inspect for: surface cracks both transverse or longitudinal; slides, sinkholes, or depressions; missing vegetative cover; animal burrows; vegetation larger than two (2) inches in diameter; accumulated liquid; and surface discoloration indicating ash discharge from the landfill.

Inspection Findings:

Nothing New -

Action Taken:

HEAVY RAINFALL LAST NIGHT PREVENTED ADDRESSING EROSION RUTTING AND WEATHERED ASH LANDFILL SCHEDULED FOR TODAY. WILL PLAN FOR TOP SOIL AND SEEDING AFTER JUNE 1ST.

Inspection for Excessive Fugitive Dust and Proper Operations to Minimize Fugitive Dust:

Inspection Findings:

NO DEFECTS

Action Taken:

None

Inspected by: Randy Boyle

Signed: Randy Boyle (Print)

Date: 5/19/17

Reviewed By: ACCJ