

Weekly CCR Landfill Inspection Form

Inspection for Structural Weakness on GREC CCR Landfill:

The inspector shall inspect for: surface cracks both transverse or longitudinal; slides, sinkholes, or depressions; missing vegetative cover; animal burrows; vegetation larger than two (2) inches in diameter; accumulated liquid; and surface discoloration indicating ash discharge from the landfill.

Inspection Findings: *NONE*

Action Taken: *NONE*

Inspection for Excessive Fugitive Dust and Proper Operations to Minimize Fugitive Dust:

Inspection Findings: *NONE*

Action Taken: *NONE*

Inspected by: *Randy Boyls*

Signed: *Randy Boyls* (Print)

Date: *5-10-18*

Reviewed By: *[Signature]*