

Inspection for Structural Weakness on GREC CCR Landfill:

Weekly CCR Landfill Inspection Form

The inspector shall inspect for: surface cracks both transverse or longitudinal; slides, sinkholes, or depressions; missing vegetative cover; animal burrows; vegetation larger than two (2) inches in diameter; accumulated liquid; and surface discoloration indicating ash discharge from the landfill.	
Inspection Findings:	
No Exceptions	
Action Taken:	
MOME TAKEN	
Inspection for Excessive Fugitive Dust and Proper Ope	erations to Minimize Fugitive Dust:
Inspection Findings:	
No EXCEPTIONS	
Action Taken:	
MONIE TAKEN	
Inspected by: Randy Bog le Signed: Romb Barrel	Date: 9-30-16
Reviewed By:	