

Weekly CCR Landfill Inspection Form

Inspection for Structural Weakness on GREC CCR Landfill:
The inspector shall inspect for: surface cracks both transverse or longitudinal; slides, sinkholes, or depressions; missing vegetative cover; animal burrows; vegetation larger than two (2) inches in diameter; accumulated liquid; and surface discoloration indicating ash discharge from the landfill.

Inspection Findings: none

Action Taken: none

Inspection for Excessive Fugitive Dust and Proper Operations to Minimize Fugitive Dust:

Inspection Findings: none

Action Taken: none

Inspected by: Randy Boyer

Signed: Randy Boyer (Print)

Date: 9-28-18

Reviewed By: Daniel [Signature]