

Weekly CCR Landfill Inspection Form

Inspection for Structural Weakness on GREC CCR Landfill:

The inspector shall inspect for: surface cracks both transverse or longitudinal; slides, sinkholes, or depressions; missing vegetative cover; animal burrows; vegetation larger than two (2) inches in diameter; accumulated liquid; and surface discoloration indicating ash discharge from the landfill.

Inspection Findings:

No Exceptions

Action Taken:

None Taken

Inspection for Excessive Fugitive Dust and Proper Operations to Minimize Fugitive Dust:

Inspection Findings:

No Exceptions

Action Taken:

None Taken

Inspected by: Johnny Smith
(Print)

Signed: Johnny Smith

Date: 11/12/15

Reviewed By: [Signature]