

## Weekly CCR Landfill Inspection Form

### Inspection for Structural Weakness on GREC CCR Landfill:

The inspector shall inspect for: surface cracks both transverse or longitudinal; slides, sinkholes, or depressions; missing vegetative cover; animal burrows; vegetation larger than two (2) inches in diameter; accumulated liquid; and surface discoloration indicating ash discharge from the landfill.

#### Inspection Findings:

No Exceptions

#### Action Taken:

None Taken

### Inspection for Excessive Fugitive Dust and Proper Operations to Minimize Fugitive Dust:

#### Inspection Findings:

No Exceptions

#### Action Taken:

None Taken

Inspected by: Randy Bugh  
(Print)

Signed: Randy Bugh

Date: 12/16/15

Reviewed By: [Signature]