

## Weekly CCR Landfill Inspection Form

### Inspection for Structural Weakness on GREC CCR Landfill:

The inspector shall inspect for: surface cracks both transverse or longitudinal; slides, sinkholes, or depressions; missing vegetative cover; animal burrows; vegetation larger than two (2) inches in diameter; accumulated liquid; and surface discoloration indicating ash discharge from the landfill.

**Inspection Finding:** None

**Action Taken:** None

### Inspection for Excessive Fugitive Dust and Proper Operations to Minimize Fugitive Dust:

**Inspection Findings:** None

**Action Taken:** None

Inspected by: Michael L. Bednar

Date: 11/29/2023

Signed By:

Michael L Bednar