

# RFQ 1451

## Questions and Answers #1

---

1. Any Installation Services Required?

A: If GRDA installing voids warranties, then we would like vendor to install.

2. Will we require EPA recycle of old batteries after replacement?

A: If GRDA receives a credit for vendor recycling, then we would like vendor to recycle.

3. What are the racking that these will go into? Are they 2-tier, 2-step, etc?

A: 2 Tier

4. What are the measurements?

A: The batteries measure 10"L x 8 ½"W in the section the rack holds and there are ten batteries on top and ten on bottom.

5. Does the delivery point have a loading dock or forklift to offload/reload shipments or would a liftgate be required?

A: The delivery point has a loading dock, fork lift, and pallet jack. Delivery hours are Mon-Thurs, 8am-3pm. Excluding any holidays