

Week: 24 – June 10 – June 16, 2024

Weekly CCR Landfill Inspection Form

Inspection for Structural Weakness on GREC CCR Landfill:

The inspector shall inspect for: surface cracks both transverse or longitudinal; slides, sinkholes, or depressions; missing vegetative cover; animal burrows; vegetation larger than two (2) inches in diameter; accumulated liquid; and surface discoloration indicating ash discharge from the landfill.

accumulated liquid; and surface discoloration indicating ash discharge from the landfill.
Inspection Finding: None
Action Taken: None
Inspection for Excessive Fugitive Dust and Proper Operations to Minimize Fugitive Dust:
·
Inspection Findings: None
Inspection Findings: None
Inspection Findings: None
Inspection Findings: None

Inspected by: Caleb Cope

Date:6/12/2024

Signed By: