

# Electrical Supplies for Diesel Backup Generator

## Q&A

1. Are you wanting chair lugs or compression lugs?

A: Compression

2. What size is the size of the bolt holes for both of the sizes?

A: Two ½” holes.

3. If compression lugs does it need a inspection window hole?

A: No inspection window.

4. If compression lugs do they need to be long barrel type?

A: Yes, long barrel type.

5. On the NEMA 3R Enclosure, is that a CT Scan?

A: It is NOT a CT Scan.

6. What size is the bolt hole on the lugs just below the enclosure?

A: ½ inch

7. Long, Short, or Standard Barrel?

A: Long

8. Peep Window?

A: No

9. On the Strut Channel, is that 1 5/8in, 7/8in, or 13/16in?

A: 1-5/8inch

10. Line 19, what voltage is the transfer switch?

A: It needs to be rated for 600V

11. Please provide more information on last item (Line 19) of RFQ

600 Amp ASCO 300 Manual  
Transfer Switch 3 Phase 3 Pole,  
Type NEMA 3R  
600v/600a Outdoor Manual Transfer Switch  
Rated for 600V