

Q&A

RFQ 1941 – FGD Atomizer Drive Upgrade

Non Mandatory Site Visit 9.5.24 Questions

1. Are you wanting to place in Reliant Cabinet?
A: Yes
2. Is there One Drive or Two?
A: We are buying 2 but are wanting to use 1 and keep the other one as a backup.
3. For the Brand, are you requiring ABB or an Equivalent?
A: Our preference is ABB
4. Are we able to take photos?
A: Yes
5. Are you wanting to keep and use the original Backpan?
A: Yes
6. There are no wires or parts that come out of the back of the panel?
A: Correct, everything is back to back and runs out of the top.
7. Are you needing the conductors coming in?
A: We (GRDA) would do the conductors
8. Run the DLO?
A: Yes
9. Is the only cabling the remote cable?
A: Yes
10. Ethernet?
A: Yes supplied cable for the remote interface controller
11. May we measure the depth of the cabinet?
A: Yes. Measurements showed 17in deep x 59in tall
12. Would the drive installed in the door need to be removed?
A: The door will need to close with drive installed
13. Tag the IO's?
A: Yes
14. Are you having to rehab the whole panel?
A: No
15. Is the overall scope in the drawing or just the dem?
A: GRDA will do the demo
16. How would you need us to circulate the airflow within the cabinet? We could install a fan.
A: We wouldn't require that. This whole room is climate controlled and would be monitored while online.
17. May we quote a fan for circulation?
A: You can however, we can ensure proper ventilation. Anything to do with the fan, we will take care of.
18. What type of training would you like us to provide once installed?
A: An informal training would be fine
19. Is this 480v?

A: Yes

20. Is this a one-time order or will there need to be duplicates ordered in the future?

A: We are looking to purchase 2 now, 1 to commission and 1 to keep as a backup/standby.

21. Is this one you're needing to replace currently down?

A: We want to replace this one now so we don't have to use parts from others to keep it operational

22. Does the vendor need to supply their own equipment to transport the drives to the destination i.e. traveling up to 2nd floor where drive panel is located?

A: GRDA has devices that can aid in lifting and installation of the drive

23. Do you need us to print off the instruction sheets for you?

A: Yes, that'd be great

24. Would we be able to mount the display panel on the outside of the doors?

A: Yes