

## RFQ 2363 – Questions & Answers

(Answers are in red)

1. I am having some difficulty locating these parts, do you happen to have the RS or another manufacturer part number or a picture or datasheet on this item?

Addressed in Amendment 1.

2. Your description says “Triplex”, indicating 3 conductors but your description also says “1 conductor”. Do you need 3 conductors or just 1?

It is three individual conductors twisted together to make a triplex conductor. It was just spelled out in the specifications as to what each individual run shall be.

3. The short description does not refer to a UL product, but rather a standard utility grade product. Will you confirm that MV-105 is absolutely required or will a product that is in full compliance with ICEA and AEIC satisfy the request?

The MV-105 specifications that were provided in Amendment 1 were just as an example for the most recent purchase that we made. This is not a sole brand purchase for the same product. You may submit a bid for an equivalent alternative to the RFQ specifications, just please submit the specifications of the product you are quoting with your bid.

4. Can you clarify the length(s) needed. I initially read this and thought 1 x 2000-ft, but then noticed “Equal Length Runs Spooled on Non-Returnable Reels” which made me wonder if 2 x 1000-ft reels or other lengths might be required?

We need 2,000 feet in total is the only requirement. Two 1000' reels of triplex conductor would be great.