

Weekly CCR Landfill Inspection Form

Inspection for Structural Weakness on GREC CCR Landfill:

The inspector shall inspect for: surface cracks both transverse or longitudinal; slides, sinkholes, or depressions; missing vegetative cover; animal burrows; vegetation larger than two (2) inches in diameter; accumulated liquid; and surface discoloration indicating ash discharge from the landfill.

Inspection Finding: None

Action Taken: None

Inspection for Excessive Fugitive Dust and Proper Operations to Minimize Fugitive Dust:

Inspection Findings: None

Action Taken: None

Inspected by: Caleb Cope

Date: December 18, 2024

Signed By:


