

RFQ 2591-MATS BOILER TUNING FOR GREC UNIT 2

Q: Can you provide a drawing of the Unit and Test Locations?

A: Drawing will be provided after contract award to successful bidder.

Q: How many locations will need to be tested?

A: Two (2) at the economizer outlet

Q: Are test probes installed and what is their connection type etc?

A: No, no test probes installed

Q: How many test ports are available at the economizer outlet?

A: Four (4) per duct, total of two ducts

Q: Do you have multipoint probes at this location for testing or do we need to bring probes to traverse the duct?

A: No, no existing multipoint probes. Yes, probes will be needed.