

# Q&A

## NON MANDATORY SITE VISIT

### SPSP POWERHOUSE ROOF SEALANT REPAIRS

Q: Are we able to take photographs?

A: Yes, what is pertinent to scope of work

Q: Are we to just remove all the old and bad and replacing with new?

A: Yes

Q: When there is big concrete patches with sealing are we to repair that or just the seams?

A: We should be able to follow the scope of work and stay with the seams

Q: Are we to repair the sealing around the transformers?

A: No

Q: Any repairs to be made along the railing?

A: Yes

Q: How far down the side does the seam go?

A: We only need to repair to the edge, that is all that was measured

Q: Do the seams run up the sides of all the units?

A: Seams run up the lids on Units 1, 2, and 3 and the 3 Square Lids

Q: Is what we're to repair all easily accessible?

A: Yes, anything is movable and we'll move for you whatever you need

Q: When Kerr was repaired, are we able to know what materials were used?

A: We are not able to provide information from previous project bids without a written request for Open Records