

RFQ 2962 – Questions & Answers

(Answers in red)

1. Can you please provide the manufacturer part number?
There is no part number as this is a request for the manufacturing of switches per the specifications provided.
2. For this project, it seems the quantity (2 motorized + 1 manual) on the excel sheet is not compliant with the quantity on the pdf file (2 manual + 1 motorized). Please, advise
This should be 1 motorized (Vertical mounted on H-Frame) + 2 manual (Horizontal mounted on switch stands).
3. Would GRDA accept vertical break switches?
No, we require Center Break Vee style switches for this application. We need to match the existing station equipment.
4. Is this RFQ for a new substation, or are is it an addition to an existing?
This RFQ is for an addition to an existing station.