

## RFQ 3191 – Questions & Answers

(Answers in red)

- 1) Would GRDA Operation and Engineering consider a quote for a fiber glass pole option for this RFQ?

Yes, but Steel is the preference. They must provide all required deliverables including PLS CADD POLE models. No guying will be allowed, and the pole must maintain all required forces.

- 2) Can you please clarify the following:

Option 1:

- One 70' Weathered Monopole
- One Anchor cage

Option 2:

- One 70' Galvanized Monopole
- One Anchor cage

Final:

- 1 pole per option for a total of 2 options, Weathering and Galvanized.

Correct, we are asking for suppliers to provide an option for galvanized, weathered, or both. We will only need one pole and anchor cage. The structures within the sub are galvanized so we will give a slight preference to galvanized.

- 3) Would GRDA evaluate an alternative bid using Engineered/Manufactured Laminated Wood Utility Structures?

At this time and for this application GRDA will not be considering laminated wood.

- 4) What is the general scope of the work and estimated project timeline?

The solicitation package includes specifications along with technical drawings for the scope of this request. We are requesting items be delivered by 11/15/25.

- 5) Is a pre-bid meeting scheduled?

There is no pre-bid meeting.

- 6) What is the delivery address?

The delivery address is 635 Hwy 69A, Pryor, OK 74362

- 7) Is there a "Buy American" requirement?

No, however it is a preference to be manufactured in the U.S. to avoid any tariff charges.