

BIDDER'S EXCEPTION STATEMENT TO TECHNICAL SPECIFICATIONS

All Bidder representations will be relied on by GRDA in its evaluation of the bid to this RFQ. One of GRDA's evaluation criteria will be the number and extent of the exceptions to GRDA's specifications. Bidders shall be presumed to agree with GRDA's specifications unless the Bidder takes specific exception to one or more of the specifications as stated in the table below. Whether or not exceptions are taken, Bidders must submit this statement as part of their bid.

Bidders must clearly identify all exceptions to specifications. Bidders must also state with specificity the reasons for taking exceptions and the proposed alternatives/specification. Bidders are cautioned against an exception that may be materially deviating from the specifications included in this RFQ. A material deviation is an exception which results in the Bidder providing goods and/or services that are substantially different than the goods and/or services GRDA requested in the RFQ. If exceptions are not identified in this statement, any exception raised following the notification of the award could result in the revocation of bid award and being rejected from further consideration.

PRINT THE WORDS "NO EXCEPTIONS" HERE _____ IF THERE ARE NO EXCEPTIONS TAKEN TO ANY OF THE SPECIFICATIONS OF THIS RFQ.

IF THERE ARE EXCEPTIONS TAKEN TO ANY OF THE SPECIFICATIONS, THEY MUST BE CLEARLY STATED IN THE TEXT BOX BELOW AND SUBMITTED AS PART OF YOUR PROPOSAL.

ANY EXCEPTION THAT MATERIALLY DEVIATES FROM A SPECIFICATION IN THIS RFQ MAY RESULT IN THE REJECTION OF THE BID FROM FUTURE CONSIDERATION.

EXCEPTIONS TO TECHNICAL SPECIFICATIONS:

Specification Data Sheet(s)

Insulators shall be furnished in accordance with the following:

| Station Post Insulator Ratings | 161 kV |
|--|---------------------------------|
| Mustang Substation - Quantity | Underhung – 20 Standard - 75 |
| Withstand, kV | |
| Impulse | 750 |
| Low frequency, dry | 485 |
| Low frequency, wet | 315 |
| Electrical distance, inches | |
| Arcing | 52 |
| Leaking | 132 (min) |
| Strength, pounds | |
| Cantilever, upright | 1,850 lbs |
| Cantilever, underhung | 1,850 lbs |
| Tension | 25,000 lbs |
| Torsional | 90,000 in-lbs |
| Compressive | 75,000 lbs |
| Bolt Circle diameter, inches | Top: 5 Bottom: 5 |
| Porcelain color shall be ANSI 70 gray | |
| Height | 62" |
| Type | Tapered or Uniform stack |