

RFQ 4071 - Split A/C Unit for 2LG MCC – Trane

Q&A

Q: Does the requested line item include a complete matched split system consisting of both the outdoor condensing unit and the indoor handler/coil, or only the outdoor unit?

A: Yes both units

Q: Is this RFQ for equipment delivery only, with all installation, startup, refrigerant piping, electrical work, and removal of existing equipment excluded?

A: Just for the purchase of the units

Q: Because the existing equipment uses R-22, will GRDA accept Trane's current direct-replacement system using its presently approved refrigerant?

A: Yes

Q: Should the replacement be configured for 460-volt, three-phase electrical service?

A: Yes

Q: Must the bidder be an authorized Trane distributor, or is a reseller acceptable when the equipment is obtained through an authorized distributor and the manufacturer's warranty transfers to GRDA?

A: As long as they get us a Trane unit.

Q: For this equipment only purchase, is the seller's warranty obligation limited to the standard Trane manufacturer warranty, or would the seller also be responsible for removal and reinstallation labor?

A: GRDA will be responsible for removal and installation

Q: Does GRDA have a required delivery date or maximum acceptable lead time?

A: Would like to get units in a reasonable time frame

Q: Must delivery include unloading at the GREC warehouse?

A: Not at the warehouse needs to be unloaded at the 2LG building on site at GREC.