RFQ 4112 – PSV PILOT VALVE FOR GREC UNIT 3

Q&A

Q: Does GRDA have a photo of the Valve Tag/Nameplate?

A: Please see photo included to this Q&A of nameplate

ANDERSON GREENWOOD CROSBY
PART NO. 2712P46/S
SET PRESS. 755 PSIG TRIM
COLD DIFF. TEST PRESS. 777.65 PSIG
CAPACITY 271346 LB/HR SAT STM
TEMP 524.63 F
SERIAL NO. 1101-1607-037765
SIZE 4 IN
PVCT
ASME
UV
NB